

### UNDERTAKING

- |    |  |
|----|--|
| 1. | I/We undertake that fool Proof arrangements shall be made to avoid mixing of PSPCL supply with that to be generated by the DG/TG Set(s)  |
| 2. | I/We undertake that the neutral of PSPCL supply is isolated during the changeover to DG/TG set supply.   |
| 3. | I/We undertake that the all relevant provisions of the IE Rules, 1956 or Regulations notified by CEA under Section 53 of the Act shall be complied with in respect of the installation and test report shall be furnished. |
| 4. | I/We undertake that a proper meter shall be provided to measure the energy generated from the DG/TG set and the data shall be supplied to PSPCL as and when asked for monitoring/energy audit                              |